



NOTES

1. Contractor is responsible for repair of adjacent curb and gutter if broken due to his operations.
2. If sawcut does not comply with this standard, contractor shall remove and replace entire curb and gutter and sufficient asphalt to accommodate the forms.
3. If removal of entire curb and gutter is required, remove to nearest expansion joint if less than five (5) feet from beginning of driveway. Any gutter section which is cracked at a point that leaves less than five (5) feet to the nearest expansion joint shall be removed and replaced.

APPROVED <i>[Signature]</i> DATE <i>7-12-78</i>		PUBLIC WORKS DIRECTOR - R.C.E. 8134	
1	revised concrete class	<i>[Signature]</i>	7-12-78
2	revised note 3	<i>[Signature]</i>	8-2-78
MARK	REVISIONS	APPR.	DATE

CITY OF RIVERSIDE	
PUBLIC WORKS DEPT. - ENGINEERING DIV.	
DRIVEWAY & CURB DEPRESSION	
EXISTING CURB & GUTTER	
STANDARD DRAWING NO. 303	